Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 14 Dated: 20-5-2025 It is certified that an inspection team headed by Shire Rom Meana (JEN)
It is certified that an inspection team headed by Shre Rom Meana (SEN)
(Name of Officers with designation) from Blilbara PHED
inspected the The Swift Model School, Patel Nagar, Near Meera Circle, Bhilwara
(Name & Address of the school) on $20-5-25$ (date of inspection) and on the basis of Water
Test Report (Attached) bearing no PHED Rout / Clem 2025-26/105 dated 20-5-25 of
Office of Senior Chemist (PHED Lab) certified that the
The Swift Model School (Name of school) has safe drinking water facilities for the students and
members of staff of the institution. School is also maintains the hygienic sanitation condition in the
school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
This certificate is valid till Three Jeans i.e. eifte 19-8-2028

1

To The Swift Model School Patel Nagar, Near Meera Circle Bhilwara (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Signature with Seal: ... Name & Address Dittle Office / Department : छत्पादन उपखण्ड भीलवा

WRINCIPAL The Swift Model School

1 | Page

10	PHED/Rout/Chem/202. TEST REP	1	District Labo ED Campus, Bapu Naga のら OF THE CHEMIC	r, Pur Road Bhilwara	ted: 20/5/25 ON OF WATER		
	tomer Name - Rishi Sar The Swift Bhilwara	nsukha t Model		Dis Blo Dated: 13	strict: Bhilwara ock: Bhilwara -05-2025		
ab	Sample ID	1	Sample D	DL-BHL/Rt/ 25-26/0360		BIS 105	500;
-	chayat / Town	175		Bhilwara		2012 Drinking Water Standards	
	age / Town			Bhilwara			
	pitation / Colony			Patel Nagar	and the set of the		
				TW The Swift Model School			e
Sou				13-05-2025		Maximum Desirable Limit	Maximum Permissible
Date of Collection				Rishi Samsukha	13.0953 80	Desi	erm
Name of Sample Taker				13-05-2025		um De Limit	um Per
Date of Receipt Testing Date				13.05.25 to 18.05.25		axim	ximu
100	ing the second		Test Results			X	Ma
SN	Parameter	Unit	Method	DL-BHL/Rt/ 25-26/0360		6.5-8.5	NE
1	pH @ 25 °C		APHA 24th Edn.20234500-H B	7.91.		0.5-0.5	
2	Conductivity @ 25 °C	µS/Cm	APHA 24th Edn.2023-2510 B	1181		500	200
3	TDS	mg/L	APHA 24th Edn.2023-2540 C	791		250	10
4	Chloride as Cl	mg/L	APHA 24th Edn.2023-4500-Cl- B	91		1.0	10
5	Fluoride as F	mg/L	APHA 24th Edn. 20234500-F C	0.73			N.
6	Nitrate as NO3	mg/L	APHA 24th Edn 2023-4500 NO3-B UV	10.09		45	
7	Sulphate as SO4	mg/L	APHA 24th Edn 20234500 SO4- E	62.4		200	4(
8	Total Alkalinity (as CaCO3)	mg/L	APHA 24th Edn 2023-2320 B	400		200	60
9	Total Hardness (as CaCO3)	mg/L	APHA 24th Edn.2023-2340 C	274	all the second second	200	6
10	Calcium Hardness (sa CaCO3)	mg/L	APHA 24th Edn.20233500-Ca B	72.0		188	5
11	Magnesium Hardness (as CaCO3)	mg/L	APHA 24th Edn.20233500-Mg B	202.00		122	4
12	Sodium as Na	mg/L	APHA 24th Edn.2023-3500 Na-B	75		-	
13	Potassium as K	mg/L	APHA 24th Edn.2023-3500-K D	8.00		-	-
14	Turbidity	NTU	APHA 24th Edn.2023-2130 B	0.00		1	-
-						1	-
						-	-
-		1				-	-
-							

Junior Chemist

PRINCIPIT. The Swift Model School

Note

1 The results given above are related to the samples as received and tested in PHED District Lab Bhilwara 2 The test report can't be regenerated/re-produced in whole or part thereof without written permission of PHED District Lab Bhilwara 3 The test report can't be used for any publicity or any legal purpose. 4 The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless and until specifically requested for retaining

5 No monetary responsibility of the laboratory as no fee is charged for the analysis of test samples and issue of test report. over a longer period.

- 6 Documents Related To MU are available in office and can be provided on request
- ----- End of Report -----

Phone No. - 01482 240320

Page 1 of 1

Email - phedlabbhilwara@gmail.com

PHED Lab Bhilwara

2



Public Health Engineering Department Office of Senior Chemist

District Lab, Bhilwara



Dated)5/5/25

<u>No. Lab / Tech (Bact.)/2024-25/93</u> To,

> **Rishi Samsukha** The Swift Model School Bhilwara

Bhilwara

Report of Bacteriological Examination of Water

Referenc	e: - Your L				Dated	12.05.25	Rishi Sam	sukha
Date of F	Receipt	13-May	and the second second		Sample Ta	aker	Rishi San	ISUKIIA
Lab Sample No.	Date Time	Date of Exam.	Village / Town / City	Source & Location	Residual Chlorine (mg/L)	Total Coli- forms (MPN / 100 mL)	E Coli (MPN / 100 mL)	Remar
369	13-May 10.50am	13-May	Bhilwara	TW The Swift Model School Patel Nagar		Nil	Nil	Sat.
		1						
				λ				
-								
-								
					1			
								1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.
4		-						
	Satisfacto	1.172.14		- Unsatisfactory				

RR

50 Senior Chemist

PHED Dist. Lab BHILWARA Dated

No. Lab / Tech (Bact.)/2024-25/ Copy to 1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur 2. Suprintending Chemist, PHED Regional Laboratory, Ajmer

Senior Chemist PHED Dist. Lab BHILWARA